

PRODUCT SPECS



CLASS 2 RUBBER INSULATING GLOVES

Arc Flash Protection

These rubber insulating gloves protect against electrical shock and should be tested every 6 months in accordance with ASTM F496, "Standard Specification for In Service Care of Insulating Gloves and Sleeves" at an authorized safety equipment testing facility. Type I natural rubber. Meet ASTM D120.



Features

- Meets ASTM D120
- Max Use Voltage AC / DC (when worn with leather protectors): 17,000 / 25,500
- Proof Test Voltage AC / DC: 20,000 / 50,000
- Made from natural rubber
- Black color
- Yellow class color label for class "2"
- 14" length
- Made in U.S.A.
- Part # LRIG-2-14-SIZE

PART #LRIG-2-14-SIZE

WWW.CHICAGOPROTECTIVE.COM